

# ENGLEWOOD AREA FIRE CONTROL DISTRICT

ADMINISTRATION CENTER  
516 Paul Morris Drive  
Englewood, FL 34223




PHONE: (941) 474-3311  
FAX: (941) 473-2600  
www.Englewood-fire.com

Kyle Brooks  
Fire Marshal  
Office: 941.474.3311  
[KBrooks@Englewood-Fire.com](mailto:KBrooks@Englewood-Fire.com)

## Approved Fire Lanes

Per the Florida Fire Prevention Code: NFPA 1:18.2.3.6.3 Fire lanes shall be marked with signs that are readily visible to the street with wording, **"NO PARKING FIRE LANE BY ORDER OF THE FIRE DEPARTMENT"**. The following items shall also be required for Fire Lanes.

- A) All signs shall be 12" in width by 18" in height
- B) White background with red letters
- C) Signs shall be a maximum of 7" in height from the roadway to the bottom of the sign
- D) Signs shall be located not more than 60" apart & within sight of the traffic flow
- E) Curb of fire lane shall be painted traffic yellow
- F) In the front of the curb shall be painted with diagonal stripes at a 45-degree angle
- G) The diagonal stripes shall be located not more than 2' apart
- H) Fire lane box shall be not more than 4' in width
- I) Within the stripes the wording "NO PARKING FIRE LANE" shall be painted within the striping in traffic yellow and shall be 12" x 12" lettering.



*"Desire to Serve, Courage to Act"*