

ENGLEWOOD AREA FIRE CONTROL DISTRICT

Administration Center
579 S Indiana Avenue
Englewood, FL 34223



PHONE: (941) 474-3311
FAX: (941) 473-2600
www.englewood-fire.com

Kyle Brooks
Fire Marshal
Office: 941.474.3311
KBrooks@Englewood-Fire.com

Approved Fire Lanes

Per the Florida Fire Prevention Code: NFPA 1:18.2.3.6.3 Fire lanes shall be marked with signs that are readily visible to the street with wording, "NO PARKING FIRE LANE BY ORDER OF THE FIRE DEPARTMENT". The following items shall also be required for Fire Lanes.

- A) All signs shall be 12" in width by 18" in height
- B) White background with red letters
- C) Signs shall be a maximum of 7" in height from the roadway to the bottom of the sign
- D) Signs shall be located not more than 60' apart & within sight of the traffic flow
- E) Curb of fire lane shall be painted traffic yellow
- F) In the front of the curb shall be painted with diagonal stripes at a 45-degree angle
- G) The diagonal stripes shall be located not more than 2' apart
- H) Fire lane box shall be not more than 4' in width
- I) Within the stripes the wording "NO PARKING FIRE LANE" shall be painted within the striping in traffic yellow and shall be 12" x 12" lettering.



"Desire to Serve, Courage to Act"